

GENERAL BUILDING CHECKLIST

ENTRANCES:	YES	NO	N/A
1. Is the entrance well lit?	✓		
2. Are floor mats provided on the inside of all entrances?	✓		
3. Are floor mats maintained in such a manner as to prevent tripping?	✓		
4. Are steps in good condition with no broken or loose steps?	✓		
5. Is a handrail installed and is it firmly attached?	✓		
6. Is there a sign directing all visitors to sign in at the office when entering the school?	✓		

HALLWAYS:	YES	NO	N/A
1. Are hallways and entrances to rooms well lit?	✓		
2. Are hallways clean and free of loose paper and debris that could create a tripping hazard?	✓		
3. Are halls free of tripping hazards (cords, book bags, boxes, etc.) that could create a tripping hazard?	✓		
4. Are the flooring materials in good condition? No loose or broken tiles, carpets not torn or bunched up.	✓		Need transition @ Bottom of Ramp
5. Are lockers, display cases, and other items securely mounted to the wall or floors?	✓		
6. Are heat registers and other devices properly maintained to prevent a tripping or catching of clothing?	✓		
7. Are fire doors not blocked open (includes classroom doors)?	✓		
8. Are fire extinguishers and fire alarm pull boxes, properly identified, accessible, and securely mounted?	✓		there are 2 fire extinguishers that need signs.
9. Do custodians barricade wet areas when mopping, stripping, and waxing floors to warn others of potential slip hazards?	✓		

STAIRS AND STAIRWAYS:	YES	NO	N/A
1. Are stairs and stairways well lit?	✓		
2. Are stairs free of clutter and trash that could create a slip/trip/fall condition?	✓		
3. Are the stairs in good condition with no broken steps or damaged or excessively worn runners?	✓		
4. For exterior steps are they covered with a non-slip coating or tread to prevent slips during wet or inclement weather?	✓		
5. Are handrails installed securely and in good condition?	✓		
6. For stairs and stair landings greater than 4 feet in height is a guardrail system in place? A guardrail consists of a top rail, mid-rail, and toe board to prevent falls from heights.	✓		

GENERAL BUILDING CHECKLIST

EXITS:	YES	NO	N/A
1. Are exits properly marked?	✓		
2. Do all exit doors open outwards with the path of egress?	✓		
3. Are exit doors chained or padlocked when employees and/or children located in the building? Chaining or padlocking an emergency exit door with employees or children in the school is a fire code violation.		✓	
4. Do all exit doors open freely and provide an unobstructed path to an outside public area?		✓	Fire exit in B1 Sticks- Gym
5. Are exit paths marked and maintained free of debris and other items that can block or partially block the exit? There must be a minimum width of 22 inches for all exit paths and doors.	✓		Exit doors stick + close Roughly

OFFICE AREAS:	YES	NO	N/A
1. Are desks and chairs appropriate for the type of work being performed?	✓		
2. Are electrical cords covered or secured to prevent a tripping hazard?	✓		
3. Are file cabinets and desk drawers kept shut when not in use?	✓		
4. Are file cabinets, shelves, partitions properly secured and free of loose items lying on top of them?	✓		

CLASSROOMS:	YES	NO	N/A
1. Are all exit doors unobstructed for quick and easy evacuation in emergency situations?	✓		
2. Are floors free from cords, toys, books and other trip hazards?	✓		
3. Are chairs, seats, and desks in good repair?	✓		
4. Are windows free of breaks and cracks?	✓		
5. Are closets and storage rooms clean and orderly?		✓	Several Closets need top Shelf cleared 18"
6. Is the room neat and clean? (Trash removed, no evidence of water intrusion, etc.)	✓		

RESTROOMS:	YES	NO	N/A
1. Are floors clean and dry to prevent slips and falls?	✓		
2. Are commodes, urinals, and sinks, secured firmly to the wall or floor as designed?	✓		
3. Is the restroom well lit?	✓		
4. Are the restrooms maintained clean and sanitary?	✓		

GENERAL BUILDING CHECKLIST

GYMNASIUMS:	YES	NO	N/A
1. Are the bleachers in good condition and provided with guardrails if greater than 4 feet from the ground elevations.		<input checked="" type="checkbox"/>	Hand Rail Neck welding.
2. Are lights protected from glass breakage?	<input checked="" type="checkbox"/>		
3. Is the floor in good condition?	<input checked="" type="checkbox"/>		
4. Are all exits properly marked and maintained?	<input checked="" type="checkbox"/>		
5. Are there mats behind the basketball goals and in other areas where students can run into or fall from heights (ropes, balance beams, parallel bars, etc.)?	<input checked="" type="checkbox"/>		
6. Are locker rooms and shower facilities kept clean and free of standing water?	<input checked="" type="checkbox"/>		

AUDITORIUMS:	YES	NO	N/A
1. Are fixed seats firmly secured to the floor?			<input checked="" type="checkbox"/>
2. Are aisles and walkways free of trip hazards?			<input checked="" type="checkbox"/>
3. Are the stairs leading to the stage provided with a handrail?			<input checked="" type="checkbox"/>
4. Are backstage areas lighted sufficiently to prevent slips and falls?			<input checked="" type="checkbox"/>
5. Is housekeeping satisfactory?			<input checked="" type="checkbox"/>

CUSTODIAN/JANITOR CLOSETS:	YES	NO	N/A
1. Are the doors shut and locked when not in use?	<input checked="" type="checkbox"/>		
2. Are all chemical containers clearly labeled with the name of the chemical and any warnings?	<input checked="" type="checkbox"/>		
3. Are items stored neat and orderly?	<input checked="" type="checkbox"/>		
4. Are the floors free of standing water or liquids?	<input checked="" type="checkbox"/>		
5. Are extension cords and power cords on equipment in good repair?	<input checked="" type="checkbox"/>		

BOILER AND MECHANICAL ROOMS:	YES	NO	N/A
1. Are the doors shut and locked when not in use?	<input checked="" type="checkbox"/>		
2. Are all chemical containers clearly labeled with the name of the chemical and any warnings?	<input checked="" type="checkbox"/>		
3. Is the room clean and orderly and not used for storage of non-essential materials and items (Holiday decorations, spare or old books, etc.)	<input checked="" type="checkbox"/>		
4. Are the floors free of standing water or liquids?	<input checked="" type="checkbox"/>		
5. Are electrical panels and breaker boxes clear of obstructions?	<input checked="" type="checkbox"/>		
6. Do electrical junction boxes, switches and receptacles have proper covers in place?	<input checked="" type="checkbox"/>		

GENERAL BUILDING CHECKLIST

COMMENTS? PLEASE WRITE THEM BELOW:

- The transition @ the bottom of Ramp may pose a tripping hazard. Needs transition piece installed.
- Gym Fire exit doors need Repair
- Fire exit door in 131 sticks.
- Gym hand Rails need welding, Safety issue if Public is in Gym
- Several Closets need top shelf cleared. 18 inch fire issue.
- Need 2 Fire extinguisher Signs